



SMA New Energy Technology (Jiangsu) Co., Ltd
No. 198 Xiangyang Road
215011 Suzhou • China
Tel: +86 512 6937 0998
Fax: +86 512 6937 3159

Manufacture's Declaration

Confirmation of Compliance with the Requirements of VFR 2014/UTE C 15-712-1

SMA New Energy Technology (Jiangsu) Co., Ltd hereby confirms that the inverter type listed below table meet the requirement of the French code of practice UTE C 15-712-1.

Brand	zeversolar
Type reference	Zeverlution 3000S
Nominal AC Power	3000W
Maximum AC Power	3000W

The inverter meets the requirements of VFR 2014/UTE C 15-712-1, along with the specifications in the data sheet and the CE declaration, by the following points:

- The certificate of the compliance with VDE 0126-1-1/A1:2012 has been issued by an accredited institute. The certificate can be downloaded from the website <http://www.zeversolar.com/>.
- The inverter meets the requirements of the French code of practice UTE C 15-712-1.
- The automatic disconnection devices integrated within the inverters with single-phase mains surveillance meet the requirements of DIN VDE 0126-1-1 / A1: 2012 with the deviation of VFR 2014 (mentioned in "Protections des installations de production raccordées au réseau public de distribution, ERDF-NOI-RES_13E, Version 5, 30/06/2013").
- The grid protection parameters can't be changed by user, an installer or by any person other than SMA (password protected).

Suzhou, 31.07.2017

SMA New Energy Technology (Jiangsu) Co., Ltd.

Sandy Gong, Safety Manager



SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road

215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159

Test Results

Power quality

Harmonic current emissions as per EN 61000-3-2			
Harmonic	Test Value in Amps	% of fund	Limit in Amps
2	0.006	0.048	1.080
3	0.112	0.86	2.300
4	0.003	0.019	0.430
5	0.054	0.413	1.140
6	0.009	0.07	0.300
7	0.004	0.03	0.770
8	0.003	0.026	0.230
9	0.018	0.141	0.400
10	0.003	0.023	0.184
11	0.019	0.147	0.330
12	0.004	0.03	0.153
13	0.012	0.091	0.210
14	0.005	0.042	0.131
15	0.015	0.113	0.150
16	0.005	0.04	0.115
17	0.014	0.105	0.132
18	0.006	0.046	0.102
19	0.014	0.104	0.118
20	0.007	0.054	0.092
21	0.014	0.104	0.107
22	0.007	0.051	0.084
23	0.011	0.085	0.098
24	0.008	0.062	0.077
25	0.01	0.078	0.090
26	0.006	0.044	0.071
27	0.009	0.07	0.083
28	0.006	0.046	0.066
29	0.009	0.071	0.078
30	0.005	0.038	0.061
31	0.007	0.056	0.073
32	0.005	0.041	0.058
33	0.004	0.034	0.068

SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road • 215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159



SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road

215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159

34	0.006	0.048	0.054
35	0.007	0.052	0.064
36	0.006	0.045	0.051
37	0.007	0.054	0.061
38	0.006	0.044	0.048
39	0.007	0.057	0.058
40	0.006	0.044	0.046
THD	-	1.06%	-

Voltage fluctuations and flicker as per EN 61000-3-3								
	Starting			Stopping			Running	
	dmax	dc	d(t)	dmax	dc	d(t)	Pst	Plt 2 hours
Measured Values	2.00%	0.00%	2.00%	1.97%	0.00%	1.97%	0.453	0.540
Limits set under EN 61000-3-3	4%	3.3%	3.3% 500ms	4%	3.3%	3.3% 500ms	1.0	0.65
Test start date	09/06/2015			Test end date			09/06/2015	
Test location	Audix Technology (Wujiang) Co., Ltd. EMC Dept							

Power factor *			
Test Voltage level	210 V	230 V	253 V
Measured value at 100%Pn	0.995	0.996	0.996
Limit	>0.95	>0.95	>0.95

* Measured at three voltage levels and at full output. The voltage maintained within $\pm 1.5\%$ of the stated level during the test.

Under/Over frequency protection

Function	Limit		Actual setting		Trip test	
	Frequency[Hz]	Time[s]	Frequency[Hz]	Time[s]	Frequency[Hz]	Time[s]
U/F Stage 1	47.5	0.2	47.5	0.16	47.50	0.156
O/F Stage 1	50.6	0.2	50.6	0.16	50.59	0.155

Under/Over voltage protection

Function	Limit		Actual setting		Trip test	
	Voltage [V]	Time [s]	Voltage [V]	Time [s]	Voltage [V]	Time [s]
U/V Stage 1	184.0	0.2	184.0	0.12	185.6	0.146
O/V Stage 1 *	253.0	600	253.0	600	257.6	563
O/V Stage 2	264.5	0.2	264.5	0.12	265.4	0.139

SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road • 215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159



SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road

215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159

*Over voltage – stage 1: 10 min mean value corresponding to EN 50160. The voltage is set to 100%Un and held for 600s. After that, the voltage is set to 112%Un. It must be switched off within 600s.

Loss of mains test

Method used	The optimized Slip-Mode Frequency Shift (SMS) method		
	25% Pn	50% Pn	100% Pn
Output power level			
Limit according to VDE 0126-1-1	5s	5s	5s
Trip time (L:+5%)	0.294s	0.328s	0.279s
Trip time (L:+4%)	0.295s	0.287s	0.292s
Trip time (L:+3%)	0.298s	0.289s	0.277s
Trip time (L:+2%)	0.291s	0.382s	0.300s
Trip time (L:+1%)	0.304s	0.395s	0.336s
Trip time (L:+0%)	0.370s	0.411s	0.505s
Trip time (L:-1%)	0.396s	0.368s	0.377s
Trip time (L:-2%)	0.387s	0.344s	0.350s
Trip time (L:-3%)	0.360s	0.369s	0.332s
Trip time (L:-4%)	0.365s	0.334s	0.345s
Trip time (L:-5%)	0.354s	0.269s	0.336s

Reconnection time measurement

Reconnection time	Under/over Voltage	Under / over Frequency	Loss of Mains
Limit	60s	60s	60s
Actual setting	60s	60s	60s
Recorded value	68s	69s	68s

DC current monitoring

A direct current feed to the low voltage grid due to a defective generator operation must lead to a disconnection within 0.2 s. (according to VDE 0126-1-1)

Function	Limit		Trip test	
	DC current [A]	Time [ms]	DC current [A]	Time [ms]
Positive DC current	1.0	200	0.98	152
Negative DC current	1.0	200	0.99	159

Residual current monitoring

Test for correct triggering in event of steadily rising residual current				
PV connection	Limit		Trip test	
	Fault current [mA]	Time [ms]	Test Current [mA]	Time [ms]

SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road • 215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159



SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road

215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159

PV+	300	300	79	131
PV-	300	300	82	123

Test for correct triggering in event of sudden rising residual current				
PV connection	Limit		Trip test	
	Fault current [mA]	Time [ms]	Test Current [mA]	Time [ms]
PV+	30	300	30.0	136
PV+	60	150	59.5	115
PV+	150	40	147.9	38
PV-	30	300	28.9	169
PV-	60	150	59.5	128
PV-	150	40	148.2	35

Array insulation resistance detection

The value of the total resistance, including the intentional resistance for array functional grounding, the expected insulation resistance of the array to ground, and the resistance of any other networks connected to ground (for example measurement networks) must not be lower than $R = (V_{MAX PV}/30 \text{ mA})$ ohms. (according to EN 62109-2)

PV connector	Test resistance value	Activation(Yes/No)	Display
PV+	200kΩ	Yes	Isolation Fault
PV-	200kΩ	Yes	Isolation Fault

SMA New Energy Technology (Jiangsu) Co., Ltd

No. 198 Xiangyang Road • 215011 Suzhou • China

Tel: +86 512 6937 0998

Fax: +86 512 6937 3159